

DATUM DER PROBENAHME	07.11.1978	17.12.1979	03.06.1980	05.11.1980	05.05.1982	09.11.1982	04.05.1983
----------------------	------------	------------	------------	------------	------------	------------	------------

PHYSIKALISCHE PARAMETER

Temperatur des Wassers	°C	11.6	12.0	10.4	11.8	9.6	11.8	10.2
Temperatur der Luft	°C					10.0	12.0	10.0
Leitfähigkeit (20 °C)	µS/cm							
Spektr. Absorptionskoeff. 254 nm	1/m							
Ergiebigkeit / Pumpmenge	l/min		2220	1950	2100	3000	3000	3600

BAKTERIOLOGIE

Aerobe mesophile Keime pro 1 ml

PC-Agar (20 °C) am 3. Tag		1						2
PC-Agar (30 °C) am 3. Tag		3						5

Fäkalkeime

Escherichia coli	100 ml	0						0
Enterokokken	100 ml	0						0

CHEMISCHE HAUPT- UND NEBENPARAMETER

Gesamthärte	°H	37.7	37.5	36.2	36.2	37.6	36.6	36.7
Karbonathärte	°H	31.5	31.3	30.5	30.5	31.2	31.2	31.0
Resthärte	°H	6.2	6.2	5.7	5.7	6.4	5.4	5.7
Oxidierbarkeit	mg/l	2.2	1.6	1.4	1.4	1.4	1.6	1.1
Totaler organ. Kohlenstoff (TOC)	mg/l							
Ammonium	mg/l	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
Nitrit	mg/l	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005
Nitrat	mg/l	28.0	31.0	32.0	34.0	30.8	28.2	28.6
Chlorid	mg/l	20.0	21.6	19.9	17.0	18.9	18.0	17.6
Phosphat (als P)	mg/l	< 0.006	0.009	< 0.006	0.009	< 0.006	0.006	< 0.006
Sulfat	mg/l							
Eisen	mg/l	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
Mangan	mg/l	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05
Freie Kohlensäure	mg/l	49.0	45.0	36.6	41.5	45.0	51.4	52.9
Sauerstoff (gelöst)	mg/l	6.15	7.88	8.8	6.7	7.94	7.01	7.9
Sauerstoffsättigung	%	61.5	79.5	85.5	64.0	74.0	68.6	74.0
pH-Wert		7.1	7.1	7.1	7.1	7.0	7.0	7.1

WEITERE METALLE

Strontium	µg/l	
Zink	µg/l	
Cadmium	µg/l	
Quecksilber	µg/l	
Blei	µg/l	

DATUM DER PROBENAHME	07.11.1983	07.05.1984	29.10.1984	01.04.1985	24.10.1985	09.04.1986	22.10.1986
----------------------	------------	------------	------------	------------	------------	------------	------------

PHYSIKALISCHE PARAMETER

Temperatur des Wassers	°C	11.8	10.0	11.4	10.2	11.3	9.9	11.4
Temperatur der Luft	°C	7.0	12.0	3.0	13.0	6.0	10.0	9.0
Leitfähigkeit (20 °C)	µS/cm							
Spektr. Absorptionskoeff. 254 nm	l/m							
Ergiebigkeit / Pumpmenge	l/min	3000	3000	3000	3080	3000	3100	9000

BAKTERIOLOGIE

Aerobe mesophile Keime pro 1 ml

PC-Agar (20 °C) am 3. Tag	2
PC-Agar (30 °C) am 3. Tag	5

Fäkalkeime

Escherichia coli	100 ml	0
Enterokokken	100 ml	0

CHEMISCHE HAUPT- UND NEBENPARAMETER

Gesamthärte	°fH	37.2	36.5	37.0	37.3	35.5	37.4	35.8
Karbonathärte	°fH	31.4	30.3	30.8	30.0	28.4	29.8	28.8
Resthärte	°fH	5.8	6.2	6.2	7.3	7.1	7.6	7.0
Oxidierbarkeit	mg/l	1.9	2.1	1.6	1.0	1.3	1.4	1.3
Totaler organ. Kohlenstoff (TOC)	mg/l							
Ammonium	mg/l	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
Nitrit	mg/l	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005
Nitrat	mg/l	27.7	30.8	34.5	41.8	38.7	38.7	38.1
Chlorid	mg/l	18.8	20.2	20.8	23.0	22.5	25.6	23.4
Phosphat (als P)	mg/l	< 0.006	0.009	0.021	0.031	< 0.006	0.006	0.006
Sulfat	mg/l							
Eisen	mg/l	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
Mangan	mg/l	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.02	< 0.02
Freie Kohlensäure	mg/l	41.4	47.7	37.3	42.0	42.2	42.0	45.3
Sauerstoff (gelöst)	mg/l	7.0	8.1	7.91	9.1	7.81	8.38	7.38
Sauerstoffsättigung	%	68.4	76.1	76.6	85.8	75.5	78.4	71.5
pH-Wert		7.0	7.1	7.1	7.1	7.1	7.0	7.0

WEITERE METALLE

Strontium	µg/l	
Zink	µg/l	
Cadmium	µg/l	
Quecksilber	µg/l	
Blei	µg/l	

DATUM DER PROBENAHME	06.04.1987	19.10.1987	11.04.1988	17.10.1988	10.04.1989	03.04.1990	07.08.1990
----------------------	------------	------------	------------	------------	------------	------------	------------

PHYSIKALISCHE PARAMETER

Temperatur des Wassers	°C	10.2	11.3	10.5	12.1	10.8	11.0	10.8
Temperatur der Luft	°C	4.0	8.0		14.0	10.0		14.0
Leitfähigkeit (20 °C)	µS/cm							637
Spektr. Absorptionskoeff. 254 nm	1/m							
Ergiebigkeit / Pumpmenge	l/min	3167	3100	3250	3167	3000	3166	3100

BAKTERIOLOGIE

Aerobe mesophile Keime pro 1 ml

PC-Agar (20 °C) am 3. Tag		0		2				
PC-Agar (30 °C) am 3. Tag		2		4				

Fäkalkeime

Escherichia coli	100 ml	0		0				
Enterokokken	100 ml	0		0				

CHEMISCHE HAUPT- UND NEBENPARAMETER

Gesamthärte	°fH	37.1	36.8	37.5	37.0	37.7	37.0	36.8
Karbonathärte	°fH	30.0	30.0	30.3	30.8	31.9	31.1	31.2
Resthärte	°fH	7.1	6.8	7.2	6.2	5.8	5.9	5.6
Oxidierbarkeit	mg/l	1.1	1.3	1.6	1.3	0.8	1.4	1.1
Totaler organ. Kohlenstoff (TOC)	mg/l							
Ammonium	mg/l	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
Nitrit	mg/l	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005
Nitrat	mg/l	37.2	42.5	40.3	31.9	37.7	24.8	28.8
Chlorid	mg/l	23.6	24.4	21.4	20.3	20.0	18.0	18.6
Phosphat (als P)	mg/l	0.006	0.009	0.009	< 0.006	0.012	0.009	0.009
Sulfat	mg/l							20.0
Eisen	mg/l	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
Mangan	mg/l	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
Freie Kohlensäure	mg/l	47.3	46.4	49.9	38.9	50.5	52.6	58.4
Sauerstoff (gelöst)	mg/l	9.1	7.76	10.03	8.16	7.64	9.38	7.92
Sauerstoffsättigung	%	85.8	75.0	95.2	80.3	73.0	90.0	75.7
pH-Wert		7.0	7.0	7.0	7.0	7.0	7.1	7.0

WEITERE METALLE

Strontium	µg/l							270
Zink	µg/l							30
Cadmium	µg/l							< 0.2
Quecksilber	µg/l							< 0.2
Blei	µg/l							< 2

DATUM DER PROBENAHME	26.02.1991	23.09.1991	16.03.1992	05.08.1992	08.03.1993	15.03.1994	06.09.1994
----------------------	------------	------------	------------	------------	------------	------------	------------

PHYSIKALISCHE PARAMETER

Temperatur des Wassers	°C	11.6	11.4	11.2	11.3	11.8	11.6	12.0
Temperatur der Luft	°C		14.0	5.0		2.0	9.0	17.0
Leitfähigkeit (20 °C)	µS/cm	659			644	665		625
Spektr. Absorptionskoeff. 254 nm	1/m							
Ergiebigkeit / Pumpmenge	l/min		3000	3000	3000	3167	3000	2900

BAKTERIOLOGIE

Aerobe mesophile Keime pro 1 ml

PC-Agar (20 °C) am 3. Tag				0	0		
PC-Agar (30 °C) am 3. Tag				1	0		

Fäkalkeime

Escherichia coli	100 ml			0	0		
Enterokokken	100 ml			0	0		

CHEMISCHE HAUPT- UND NEBENPARAMETER

Gesamthärte	°fH	37.5	38.4	37.5	36.5	37.4	39.1	35.8
Karbonathärte	°fH	31.7	32.0	30.9	30.5	30.6	31.5	29.8
Resthärte	°fH	5.8	6.4	6.6	6.0	6.8	7.6	6.0
Oxidierbarkeit	mg/l	1.7	1.0	1.6	1.0	1.4	1.0	1.0
Totaler organ. Kohlenstoff (TOC)	mg/l							
Ammonium	mg/l	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
Nitrit	mg/l	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005
Nitrat	mg/l	33.2	33.7	33.7	31.7	39.4	39.1	32.7
Chlorid	mg/l	22.1	18.9	20.3	20.7	21.5	20.0	17.6
Phosphat (als P)	mg/l	< 0.006	0.006	0.009	0.006	0.006	0.009	0.006
Sulfat	mg/l	19.0			23.9	25.6	28.7	23.7
Eisen	mg/l	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
Mangan	mg/l	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
Freie Kohlensäure	mg/l	54.2	55.5	49.3	48.6	56.5	60.1	53.5
Sauerstoff (gelöst)	mg/l	7.59	7.27	7.58	8.18	7.39	7.44	7.43
Sauerstoffsättigung	%	73.9	70.4	73.0	79.1	72.2	72.4	73.0
pH-Wert		7.0	7.1	7.0	7.0	7.0	7.0	7.1

WEITERE METALLE

Strontium	µg/l	270			290	260		300
Zink	µg/l	70			50	< 20		60
Cadmium	µg/l	< 0.2			< 0.2	< 0.2		< 0.2
Quecksilber	µg/l	< 0.2			< 0.2	< 0.2		< 0.2
Blei	µg/l	< 2			< 2	< 2		< 2

DATUM DER PROBENAHME	01.03.1995	05.09.1995	06.03.1996	01.10.1996	03.09.1997	01.09.1998	02.03.1999
----------------------	------------	------------	------------	------------	------------	------------	------------

PHYSIKALISCHE PARAMETER

Temperatur des Wassers	°C	12.0	11.4	11.6	12.4	11.6	11.8	11.4
Temperatur der Luft	°C	3.0			9.0	18.0	14.0	
Leitfähigkeit (20 °C)	µS/cm	628			647	658	664	680
Spektr. Absorptionskoeff. 254 nm	1/m							
Ergiebigkeit / Pumpmenge	l/min	2200	2900	2700	2830	3400	3300	3300

BAKTERIOLOGIE

Aerobe mesophile Keime pro 1 ml

PC-Agar (20 °C) am 3. Tag		1			0	1	0	1
PC-Agar (30 °C) am 3. Tag		2			1	5	1	0

Fäkalkeime

Escherichia coli	100 ml	0			0	0	0	0
Enterokokken	100 ml	0			0	0	0	0

CHEMISCHE HAUPT- UND NEBENPARAMETER

Gesamthärte	°fH	35.8	34.3	35.9	36.1	35.9	36.1	36.5
Karbonathärte	°fH	30.3	29.3	30.5	29.3	29.6	30.6	31.0
Resthärte	°fH	5.5	5.0	5.4	6.8	6.3	5.5	5.5
Oxidierbarkeit	mg/l	1.7	1.1	1.3	1.1	1.0	1.3	1.4
Totaler organ. Kohlenstoff (TOC)	mg/l							
Ammonium	mg/l	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	0.02	< 0.01
Nitrit	mg/l	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	< 0.002	< 0.002
Nitrat	mg/l	32.6	32.3	28.7	27.7	28.0	27.5	29.0
Chlorid	mg/l	17.8	19.8	20.2	23.7	26.2	26.0	26.0
Phosphat (als P)	mg/l	0.006	0.006	0.009	0.011	0.013	0.008	0.009
Sulfat	mg/l	20.8	20.3	22.4	24.4	25.1	27.0	25.0
Eisen	mg/l	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.01	0.01
Mangan	mg/l	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.01	< 0.01
Freie Kohlensäure	mg/l	44.5	41.5	45.5	39.8	34.5	41.0	39.0
Sauerstoff (gelöst)	mg/l	8.8	7.2	8.0	6.66	7.25	7.65	8.0
Sauerstoffsättigung	%	86.4	69.8	77.9	66.0	70.5	75.0	78.0
pH-Wert		7.0	7.0	7.1	7.0	7.1	7.1	7.15

WEITERE METALLE

Strontium	µg/l				330			
Zink	µg/l				60			
Cadmium	µg/l				< 0.2			
Quecksilber	µg/l				< 0.2			
Blei	µg/l				< 2			

DATUM DER PROBENAHME	08.09.1999	07.03.2000	05.09.2000	13.03.2001	19.09.2001	20.03.2002	25.09.2002
----------------------	------------	------------	------------	------------	------------	------------	------------

PHYSIKALISCHE PARAMETER

Temperatur des Wassers	°C	13.7	11.4	12.3	11.7	13.4	11.7	13.2
Temperatur der Luft	°C	21.0	1.0	13.0	7.0	17.0	12.0	5.5
Leitfähigkeit (20 °C)	µS/cm			643	671			632
Spektr. Absorptionskoeff. 254 nm	1/m							
Ergiebigkeit / Pumpmenge	l/min	3333	3250	3250				

BAKTERIOLOGIE

Aerobe mesophile Keime pro 1 ml

PC-Agar (20 °C) am 3. Tag			0	0	2	2	1
PC-Agar (30 °C) am 3. Tag			3	2	3	6	5

Fäkalkeime

Escherichia coli	100 ml		0	0	0	0	0
Enterokokken	100 ml		0	0	0	0	0

CHEMISCHE HAUPT- UND NEBENPARAMETER

Gesamthärte	°fH	34.9	35.2	34.7	36.0	35.4	35.3	33.3
Karbonathärte	°fH	29.6	30.9	30.1	31.5	31.0	31.9	29.4
Resthärte	°fH	5.3	4.3	4.6	4.5	4.4	3.4	3.9
Oxidierbarkeit	mg/l	1.0	1.6	1.0	1.0	0.8	1.4	1.6
Totaler organ. Kohlenstoff (TOC)	mg/l							
Ammonium	mg/l	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01
Nitrit	mg/l		< 0.002	< 0.002	< 0.002	< 0.002	< 0.002	< 0.002
Nitrat	mg/l	27.0	25.0	24.5	24.5	24.0	21.0	21.5
Chlorid	mg/l	28.0	25.0	25.5	24.0	24.5	22.5	20.0
Phosphat (als P)	mg/l	0.009	0.01	0.003	0.009	0.008	0.009	0.008
Sulfat	mg/l	28.0	23.0	24.0	24.5	25.5	22.5	22.0
Eisen	mg/l	0.07	0.09	< 0.01	< 0.01	0.01	0.04	0.01
Mangan	mg/l	0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01
Freie Kohlensäure	mg/l	35.0	35.0	40.0	41.0	37.0	40.0	34.0
Sauerstoff (gelöst)	mg/l	7.25	8.7	7.3	7.25	6.9	7.45	5.3
Sauerstoffsättigung	%	74.0	84.0	72.0	71.0	70.0	73.0	54.0
pH-Wert		7.1	7.35	7.15	7.15	7.2	7.25	7.1

WEITERE METALLE

Strontium	µg/l	
Zink	µg/l	
Cadmium	µg/l	
Quecksilber	µg/l	
Blei	µg/l	

DATUM DER PROBENAHME	12.03.2003	06.10.2004	21.03.2005	20.09.2006	26.03.2007	14.10.2008	20.09.2010
----------------------	------------	------------	------------	------------	------------	------------	------------

PHYSIKALISCHE PARAMETER

Temperatur des Wassers	°C	11.4	12.7	11.5	11.7	11.7	13.1	12.2
Temperatur der Luft	°C	12.0	20.0	12.0	16.0		18.0	7.0
Leitfähigkeit (20°C)	µS/cm	671	665	670	668	642	585	635
Spektr. Absorptionskoeff. 254 nm	1/m		1.1	1.4		0.9	1.4	1.2
Ergiebigkeit / Pumpmenge	l/min							

BAKTERIOLOGIE

Aerobe mesophile Keime pro 1 ml

PC-Agar (20°C) am 3. Tag	1	0	0	1	0	0	0
PC-Agar (30°C) am 3. Tag	1	2	0	0	0	1	2

Fäkalkeime

Escherichia coli	100 ml	0	0	0	0	0	0
Enterokokken	100 ml	0	0	0	0	0	0

CHEMISCHE HAUPT- UND NEBENPARAMETER

Gesamthärte	°fH	35.6	34.8	35.1	33.6	33.2	31.4	32.9
Karbonathärte	°fH	31.6	30.1	30.1	29.7	29.4	28.1	28.9
Resthärte	°fH	4.0	4.7	5.0	3.9	3.8	3.3	4.0
Oxidierbarkeit	mg/l	1.1	1.0					
Totaler organ. Kohlenstoff (TOC)	mg/l		0.6	0.6	0.6	0.6	0.7	0.7
Ammonium	mg/l	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01
Nitrit	mg/l	< 0.002	< 0.002	< 0.002	< 0.002	< 0.002	< 0.002	< 0.002
Nitrat	mg/l	21.5	22.5	24.5	20.5	21.0	19.5	21.0
Chlorid	mg/l	25.0	24.5	34.5	39.0	32.5	22.0	36.0
Phosphat (als P)	mg/l	0.007	0.007	0.003	0.007	0.006	< 0.002	0.01
Sulfat	mg/l	23.0	29.0	25.5	26.0	24.5	19.5	23.0
Eisen	mg/l	0.03	< 0.01	0.07	< 0.01	< 0.01	< 0.01	< 0.01
Mangan	mg/l	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01
Freie Kohlensäure	mg/l	42.0	37.0	32.0	31.0	30.0	18.0	30.0
Sauerstoff (gelöst)	mg/l	6.95	7.2	7.6	7.75	8.0	6.65	7.3
Sauerstoffsättigung	%	68.0	72.0	74.0	75.0	78.0	67.0	72.0
pH-Wert		7.15	7.15	7.25	7.55	7.3	7.4	7.35

WEITERE METALLE

Strontium	µg/l	277						276
Zink	µg/l	133						7
Cadmium	µg/l	< 0.2						< 0.2
Quecksilber	µg/l	< 0.2						< 0.2
Blei	µg/l	< 1						< 1

DATUM DER PROBENAHME	14.03.2011	09.10.2012	08.04.2013	23.09.2014	12.03.2015	26.09.2016	22.03.2017
----------------------	------------	------------	------------	------------	------------	------------	------------

PHYSIKALISCHE PARAMETER

Temperatur des Wassers	°C	11.5	13.6	11.7	13.2	12.4	13.5	12.1
Temperatur der Luft	°C							
Leitfähigkeit (20 °C)	µS/cm	656	648	659	631	653	606	703
Spektr. Absorptionskoeff. 254 nm	1/m	1.1	1.2	1.1	1.1	1.1	1.0	1.0
Ergiebigkeit / Pumpmenge	l/min							

BAKTERIOLOGIE

Aerobe mesophile Keime pro 1 ml

PC-Agar (20 °C) am 3. Tag		0						
PC-Agar (30 °C) am 3. Tag		0	0	0	0	5	0	0
Fäkalkeime								
Escherichia coli	100 ml	0	0	0	0	0	0	0
Enterokokken	100 ml	0	0	0	0	0	0	17

CHEMISCHE HAUPT- UND NEBENPARAMETER

Gesamthärte	°fH	34.2	33.4	33.9	32.4	33.7	31.3	32.7
Karbonathärte	°fH	29.8	30.5	30.3	29.7	30.8	29.0	29.8
Resthärte	°fH	4.4	2.9	3.6	2.7	2.9	2.3	2.9
Oxidierbarkeit	mg/l							
Totaler organ. Kohlenstoff (TOC)	mg/l	0.6	0.6	0.6	0.6	0.5	0.3	0.3
Ammonium	mg/l	< 0.01	< 0.05	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01
Nitrit	mg/l	< 0.002	< 0.002	< 0.002	< 0.002	< 0.002	< 0.002	< 0.002
Nitrat	mg/l	21.5	21.0	20.8	17.4	18.4	17.2	19.2
Chlorid	mg/l	40.0	32.0	39.6	32.7	34.7	28.2	32.2
Phosphat (als P)	mg/l	0.008	0.01	0.005	0.009	0.011	0.011	0.008
Sulfat	mg/l	26.0	22.5	20.4	24.5	23.5	22.1	24.2
Eisen	mg/l	< 0.01	< 0.01	< 0.01				
Mangan	mg/l	< 0.01	< 0.01	< 0.01				
Freie Kohlensäure	mg/l	25.0	28.0	22.0	29.0	24.0	19.0	19.0
Sauerstoff (gelöst)	mg/l	8.15	7.65	8.2	6.2	7.7	7.75	8.35
Sauerstoffsättigung	%	79.0	78.0	80.0	63.0	76.0	79.0	82.0
pH-Wert		7.4	7.4	7.5	7.35	7.45	7.4	7.7

WEITERE METALLE

Strontium	µg/l	
Zink	µg/l	
Cadmium	µg/l	
Quecksilber	µg/l	
Blei	µg/l	

DATUM DER PROBENAHME	22.08.2018	27.02.2019	23.09.2020	02.03.2021
----------------------	------------	------------	------------	------------

PHYSIKALISCHE PARAMETER

Temperatur des Wassers	°C	12.9	13.2	13.3	12.8
Temperatur der Luft	°C				
Leitfähigkeit (20 °C)	µS/cm	658	651	643	655
Spektr. Absorptionskoeff. 254 nm	1/m	1.0	1.1	0.9	1.0
Ergiebigkeit / Pumpmenge	l/min				

BAKTERIOLOGIE

Aerobe mesophile Keime pro 1 ml

PC-Agar (20 °C) am 3. Tag

PC-Agar (30 °C) am 3. Tag

0 20 5

Fäkalkeime

Escherichia coli	100 ml	0	0	0	0
Enterokokken	100 ml	0	0	0	0

CHEMISCHE HAUPT- UND NEBENPARAMETER

Gesamthärte	°fH	33.2	32.7	32.8	33.1
Karbonathärte	°fH	29.8	29.6	29.8	30.1
Resthärte	°fH	3.4	3.1	3.0	3.0
Oxidierbarkeit	mg/l				
Totaler organ. Kohlenstoff (TOC)	mg/l	0.4	0.5	0.7	0.8
Ammonium	mg/l	< 0.01	< 0.01	< 0.01	< 0.01
Nitrit	mg/l	< 0.002	< 0.002	< 0.002	< 0.002
Nitrat	mg/l	18.3	22.3	18.6	19.6
Chlorid	mg/l	37.7	35.9	32.1	33.8
Phosphat (als P)	mg/l	0.01	0.011	0.012	0.012
Sulfat	mg/l	26.9	24.4	25.7	23.5
Eisen	mg/l				
Mangan	mg/l				
Freie Kohlensäure	mg/l	25.0	20.0	28.0	32.0
Sauerstoff (gelöst)	mg/l	7.2	8.95	7.2	8.5
Sauerstoffsättigung	%	72.0	90.0	72.0	85.0
pH-Wert		7.4	7.7	7.4	7.2

WEITERE METALLE

Strontium	µg/l
Zink	µg/l
Cadmium	µg/l
Quecksilber	µg/l
Blei	µg/l